

Cat 3412 ,800 kVA ,10,000 HR Good Used Generator

Cat 3412 ,Generator 10,000 HR 800 KVA

Good Used Generator , Full Load Testing

Running Hours  10,000 HR



GENERATOR SET		
MODEL		800F
YEAR OF MANUFACTURE		1999
RATED POWER-PRP		
725		KVA
580		KW
0.8		COS
50		HERTZ
PHASE		3 FASE
RATED VOLTAGE	400 / 230 V	TENSION
RATED CURRENT	1046.5 A	CORRIENTE
RATED R.P.M	1500	RPM
MAXIMUM ALTITUDE	152.4 m	ALTITUD MIA
TEMPERATURE	40 °C	AMBIENTE
MASS	10460 Kg	PESO
GENERATOR	9LW00254	ATERNADOR
GENERATOR CONNECTION	S'STAR	ALTERNATIVE CONNECTION
RATING ISO 8528-3	BR	POTENCIA ISO 8528-3
GENERATOR ENCLOSURE	IP22	ALTERNATIVE CUBE
INSULATION CLASS	H	Aluminium class
EXCITATION VOLTAGE	45V	EXCITATION VOLTAGE
EXCITATION CURRENT	9.4 A	EXCITATION CURRY
ENGINE	1EZ00627	MOTOR

ELASHRAFI ENERGY
Egypt Address:
Alexandria, Cairo desert road Kilo m23
merghem
phone : 034702536 / 01000093317

Location



More INFo

